



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 207 Court Street South      Lab ID: 30756024001      Collected: 02/07/25 07:00      Received: 02/13/25 18:00      Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.061   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 13:55 | 7440-50-8 |      |
| Lead                          | 0.75    | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 13:55 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 243 S Court St. Lab ID: 30756024002 Collected: 02/07/25 05:30 Received: 02/13/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.073   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 14:04 | 7440-50-8 |      |
| Lead                          | 0.31J   | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 14:04 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 374 Lightner Ave Lab ID: 30756024003 Collected: 02/06/25 07:05 Received: 02/13/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.13    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 14:06 | 7440-50-8 |      |
| Lead                          | 1.7     | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 14:06 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 364 Holt Lane Lab ID: 30756024004 Collected: 02/06/25 07:27 Received: 02/13/25 18:00 Matrix: Drinking Water

| Parameters                    | Results      | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|--------------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |              | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | <b>0.030</b> | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 14:09 | 7440-50-8 |      |
| Lead                          | <b>0.64</b>  | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 14:09 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

| Sample: 325 Silo Lane      Lab ID: 30756024005      Collected: 02/05/25 11:00      Received: 02/13/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|---|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters  | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW  |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8  |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver   |         |       |              |        |    |          |                |           |      |
| Copper  | 0.080   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 14:12 | 7440-50-8 |      |
| Lead  | 1.6     | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 14:12 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 472 Underwood Road Lab ID: 30756024006 Collected: 02/06/25 05:45 Received: 02/13/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.24    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 14:14 | 7440-50-8 |      |
| Lead                          | 13.7    | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 14:14 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 526 Randolph Street East Lab ID: 30756024007 Collected: 02/06/25 06:20 Received: 02/13/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.16    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 14:23 | 7440-50-8 |      |
| Lead                          | 0.33J   | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 14:23 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

| Sample: 120 Rader Road        |              | Lab ID: 30756024008   | Collected: 02/06/25 05:30 | Received: 02/13/25 18:00 | Matrix: Drinking Water |          |                |           |      |
|-------------------------------|--------------|---|---------------------------|--------------------------|------------------------|----------|----------------|-----------|------|
| Parameters                    | Results      | Units   | Report Limit              | MDL                      | DF                     | Prepared | Analyzed       | CAS No.   | Qual |
| <b>BVR 200.8 MET ICPMS DW</b> |              | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |                           |                          |                        |          |                |           |      |
| Copper                        | <b>0.056</b> | mg/L  | 0.0025                    | 0.0013                   | 1                      |          | 02/18/25 14:25 | 7440-50-8 |      |
| Lead                          | <b>0.17J</b> | ug/L  | 0.50                      | 0.076                    | 1                      |          | 02/18/25 14:25 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 399 Shady Oak Lane Lab ID: 30756024009 Collected: 02/06/25 07:30 Received: 02/13/25 18:00 Matrix: Drinking Water

| Parameters                        | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-----------------------------------|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| BVR 200.8 MET ICPMS DW            |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8      |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver |         |       |              |        |    |          |                |           |      |
| Copper                            | 0.13    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 14:28 | 7440-50-8 |      |
| Lead                              | 0.23J   | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 14:28 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 2697 Brush Road      Lab ID: 30756024010      Collected: 02/07/25 06:15      Received: 02/13/25 18:00      Matrix: Drinking Water

| Parameters  | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|---|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |         |       |              |        |    |          |                |           |      |
| Copper  | 0.085   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 14:34 | 7440-50-8 |      |
| Lead  | 1.0     | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 14:34 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

| Sample: 542 Mayapple Trail      Lab ID: 30756024011      Collected: 02/07/25 08:30      Received: 02/13/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|--|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters   | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW      Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver  |         |       |              |        |    |          |                |           |      |
| Copper   | 0.019   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 14:42 | 7440-50-8 |      |
| Lead   | 0.18J   | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 14:42 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 384 Fleshman Dr. Lab ID: 30756024012 Collected: 02/06/25 08:09 Received: 02/13/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.028   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 14:51 | 7440-50-8 |      |
| Lead                          | ND      | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 14:51 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

| Sample: 475 Anderson Rd      Lab ID: 30756024013      Collected: 02/10/25 08:05      Received: 02/13/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|---|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters  | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW  |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8  |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver   |         |       |              |        |    |          |                |           |      |
| Copper  | 0.12    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 14:59 | 7440-50-8 |      |
| Lead  | 4.0     | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 14:59 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 299 Highland Circle Lab ID: 30756024014 Collected: 02/08/25 18:30 Received: 02/13/25 18:00 Matrix: Drinking Water

| Parameters                    | Results      | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|--------------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |              | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | <b>0.063</b> | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 15:01 | 7440-50-8 |      |
| Lead                          | <b>0.23J</b> | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 15:01 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 367 Lightner Ave      Lab ID: 30756024015      Collected: 02/10/25 10:00      Received: 02/13/25 18:00      Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.11    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 15:04 | 7440-50-8 |      |
| Lead                          | 12.2    | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 15:04 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

**Sample: 199 Church Street**      **Lab ID: 30756024016**      Collected: 02/10/25 08:00      Received: 02/13/25 18:00      Matrix: Drinking Water

| Parameters                        | Results | Units  | Report Limit | MDL     | DF | Prepared       | Analyzed       | CAS No.   | Qual |
|-----------------------------------|---------|--|--------------|---------|----|----------------|----------------|-----------|------|
| <b>BVR 200.8 ICPMS Metals, DW</b> |         | Analytical Method: EPA 200.8      Preparation Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |         |    |                |                |           |      |
| Copper                            | 0.20    | mg/L   | 0.0025       | 0.00064 | 1  | 02/19/25 03:07 | 02/19/25 10:47 | 7440-50-8 |      |
| Lead                              | 1.0     | ug/L   | 0.50         | 0.054   | 1  | 02/19/25 03:07 | 02/19/25 10:47 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 231 Third Street Lab ID: 30756024017 Collected: 02/10/25 06:15 Received: 02/13/25 18:00 Matrix: Drinking Water

| Parameters                    | Results      | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|--------------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |              | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | <b>0.034</b> | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 15:07 | 7440-50-8 |      |
| Lead                          | <b>0.38J</b> | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 15:07 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

| Sample: 291 Kearns Street      Lab ID: 30756024018      Collected: 02/05/25 05:45      Received: 02/13/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|---|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters  | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW  |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8  |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver   |         |       |              |        |    |          |                |           |      |
| Copper  | 0.094   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 15:10 | 7440-50-8 |      |
| Lead  | 1.5     | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 15:10 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 695 Wildwood Ave. Lab ID: 30756024019 Collected: 02/10/25 06:30 Received: 02/13/25 18:00 Matrix: Drinking Water

| Parameters                    | Results      | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|--------------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |              | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | <b>0.023</b> | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 15:12 | 7440-50-8 |      |
| Lead                          | <b>5.3</b>   | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 15:12 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 360 Ruffner Drive Lab ID: 30756024020 Collected: 02/10/25 07:13 Received: 02/13/25 18:00 Matrix: Drinking Water

| Parameters                        | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-----------------------------------|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| BVR 200.8 MET ICPMS DW            |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8      |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver |         |       |              |        |    |          |                |           |      |
| Copper                            | 0.093   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 15:15 | 7440-50-8 |      |
| Lead                              | 3.1     | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 15:15 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 16858 Seneca Trail N Lab ID: 30756024021 Collected: 02/09/25 07:04 Received: 02/13/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.049   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 15:18 | 7440-50-8 |      |
| Lead                          | 2.8     | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 15:18 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 1235 Washington Street East    Lab ID: 30756024022    Collected: 02/10/25 09:00    Received: 02/13/25 18:00    Matrix: Drinking Water

| Parameters                        | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-----------------------------------|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| BVR 200.8 MET ICPMS DW            |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8      |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver |         |       |              |        |    |          |                |           |      |
| Copper                            | 0.13    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 15:21 | 7440-50-8 |      |
| Lead                              | 1.6     | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 15:21 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 202 Van Sickler Dr. Lab ID: 30756024023 Collected: 02/13/25 08:30 Received: 02/13/25 18:00 Matrix: Drinking Water

| Parameters                    | Results       | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |               | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | <b>0.0090</b> | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 15:23 | 7440-50-8 |      |
| Lead                          | <b>0.48J</b>  | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 15:23 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30756024

| Sample: 281 Court Street South      Lab ID: 30756024024      Collected: 02/11/25 06:30      Received: 02/13/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|--|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters   | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW   |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8   |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver  |         |       |              |        |    |          |                |           |      |
| Copper   | 0.075   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 15:31 | 7440-50-8 |      |
| Lead   | 0.69    | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 15:31 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30756024

Sample: 213 Comstock Street Lab ID: 30756024025 Collected: 02/06/25 07:00 Received: 02/13/25 18:00 Matrix: Drinking Water

| Parameters                        | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-----------------------------------|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Analytical Method: EPA 200.8      |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver |         |       |              |        |    |          |                |           |      |
| Copper                            | 0.16    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/18/25 15:34 | 7440-50-8 |      |
| Lead                              | 1.0     | ug/L  | 0.50         | 0.076  | 1  |          | 02/18/25 15:34 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30756024

| Sample: 368 Echols Lane       |              | Lab ID: 30756024026   | Collected: 02/06/25 05:30 | Received: 02/13/25 18:00 | Matrix: Drinking Water |          |                |           |      |
|-------------------------------|--------------|---|---------------------------|--------------------------|------------------------|----------|----------------|-----------|------|
| Parameters                    | Results      | Units   | Report Limit              | MDL                      | DF                     | Prepared | Analyzed       | CAS No.   | Qual |
| <b>BVR 200.8 MET ICPMS DW</b> |              | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |                           |                          |                        |          |                |           |      |
| Copper                        | <b>0.028</b> | mg/L  | 0.0025                    | 0.0013                   | 1                      |          | 02/18/25 15:37 | 7440-50-8 |      |
| Lead                          | <b>0.96</b>  | ug/L  | 0.50                      | 0.076                    | 1                      |          | 02/18/25 15:37 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

| Sample: 156 FEAMSTER RD      Lab ID: 30758568001      Collected: 02/18/25 07:30      Received: 02/25/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|---|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters  | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| <b>BVR 200.8 MET ICPMS DW</b>   |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver   |         |       |              |        |    |          |                |           |      |
| Copper  | 0.0017J | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 10:57 | 7440-50-8 |      |
| Lead  | 1.3     | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 10:57 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 186 LEE STREET NORTH Lab ID: 30758568002 Collected: 02/24/25 06:30 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.035   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:05 | 7440-50-8 |      |
| Lead                          | 0.17J   | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:05 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 221 ALDERSON STREET Lab ID: 30758568003 Collected: 02/17/25 08:29 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.039   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:08 | 7440-50-8 |      |
| Lead                          | 0.26J   | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:08 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307

Pace Project No.: 30758568

Sample: 374 COURT STREET SOUTH      Lab ID: 30758568004      Collected: 02/24/25 07:00      Received: 02/25/25 18:00      Matrix: Drinking Water

| Parameters                    | Results   | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---|-------|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |       |              |        |    |          |                |           |      |
| Copper                        | 0.032   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:10 | 7440-50-8 |      |
| Lead                          | 1.3   | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:10 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30758568

| Sample: 202 FRANCES WAY      Lab ID: 30758568005      Collected: 02/08/25 07:00      Received: 02/25/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|---|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters  | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW      Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver   |         |       |              |        |    |          |                |           |      |
| Copper  | 0.094   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:13 | 7440-50-8 | H3   |
| Lead  | 0.80    | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:13 | 7439-92-1 | H3   |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 1621 WASHINGTON STREET EAST      Lab ID: 30758568006      Collected: 02/24/25 11:00      Received: 02/25/25 18:00      Matrix: Drinking Water

| Parameters                        | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-----------------------------------|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| BVR 200.8 MET ICPMS DW            |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8      |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver |         |       |              |        |    |          |                |           |      |
| Copper                            | 0.074   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:21 | 7440-50-8 |      |
| Lead                              | 15.3    | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:21 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 363 LONGVIEW AVENUE Lab ID: 30758568007 Collected: 02/18/25 06:40 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                        | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-----------------------------------|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| BVR 200.8 MET ICPMS DW            |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8      |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver |         |       |              |        |    |          |                |           |      |
| Copper                            | 0.050   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:24 | 7440-50-8 |      |
| Lead                              | 3.2     | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:24 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

| Sample: 259 WALNUT ST      Lab ID: 30758568008      Collected: 02/24/25 09:00      Received: 02/25/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|---|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters  | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW      Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver   |         |       |              |        |    |          |                |           |      |
| Copper  | 0.0054  | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:27 | 7440-50-8 |      |
| Lead  | 0.38J   | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:27 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

| Sample: 224 BROWN ROAD      Lab ID: 30758568009      Collected: 02/22/25 10:15      Received: 02/25/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|--|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters   | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW   |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8   |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver  |         |       |              |        |    |          |                |           |      |
| Copper   | 0.0049  | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:29 | 7440-50-8 |      |
| Lead   | 3.3     | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:29 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30758568

| Sample: 145 RAY DRIVE      Lab ID: 30758568010      Collected: 02/23/25 10:00      Received: 02/25/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|---|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters  | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW      Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver   |         |       |              |        |    |          |                |           |      |
| Copper  | 0.021   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:32 | 7440-50-8 |      |
| Lead  | 3.1     | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:32 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30758568

| Sample: 153 BAKER STREET      Lab ID: 30758568011      Collected: 02/21/25 06:20      Received: 02/25/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|--|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters   | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW   |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8   |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver  |         |       |              |        |    |          |                |           |      |
| Copper   | 0.0066  | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:35 | 7440-50-8 |      |
| Lead   | ND      | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:35 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 1227 BRUSH ROAD Lab ID: 30758568012 Collected: 02/19/25 04:45 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.13    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:37 | 7440-50-8 |      |
| Lead                          | 3.2     | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:37 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

| Sample: 344 CHURCH STREET      Lab ID: 30758568013      Collected: 02/21/25 02:00      Received: 02/25/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|---|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters  | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW  |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8  |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver   |         |       |              |        |    |          |                |           |      |
| Copper  | 0.0018J | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:40 | 7440-50-8 |      |
| Lead  | 0.27J   | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:40 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 1017 WASHINGTON STREET EAST      Lab ID: 30758568014      Collected: 02/14/25 10:00      Received: 02/25/25 18:00      Matrix: Drinking Water

| Parameters                    | Results      | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|--------------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |              | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | <b>0.086</b> | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:43 | 7440-50-8 |      |
| Lead                          | <b>0.45J</b> | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:43 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

| Sample: 364 OAK STREET      Lab ID: 30758568015      Collected: 02/17/25 07:00      Received: 02/25/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|--|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters   | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW   |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8   |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver  |         |       |              |        |    |          |                |           |      |
| Copper   | 0.052   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:46 | 7440-50-8 |      |
| Lead   | 0.51    | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:46 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 185 BRANDON DRIVE Lab ID: 30758568016 Collected: 02/20/25 06:30 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.095   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:54 | 7440-50-8 |      |
| Lead                          | ND      | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:54 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 1410 STONEHOUSE ROAD Lab ID: 30758568017 Collected: 02/24/25 05:05 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                        | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-----------------------------------|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| BVR 200.8 MET ICPMS DW            |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8      |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver |         |       |              |        |    |          |                |           |      |
| Copper                            | 0.0050  | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:56 | 7440-50-8 |      |
| Lead                              | 0.094J  | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:56 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30758568

| Sample: 1094 FAIRVIEW ROAD      Lab ID: 30758568018      Collected: 02/23/25 08:00      Received: 02/25/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|--|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters   | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW   |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8   |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver  |         |       |              |        |    |          |                |           |      |
| Copper   | 0.17    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 11:59 | 7440-50-8 |      |
| Lead   | 0.28J   | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 11:59 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 305 NORTH JEFFERSON STREET Lab ID: 30758568019 Collected: 02/21/25 09:30 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                        | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-----------------------------------|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| BVR 200.8 MET ICPMS DW            |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8      |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver |         |       |              |        |    |          |                |           |      |
| Copper                            | 0.0025J | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 12:02 | 7440-50-8 |      |
| Lead                              | 0.52    | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 12:02 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 757 COLEMAN DRIVE Lab ID: 30758568020 Collected: 02/20/25 07:00 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.060   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 12:05 | 7440-50-8 |      |
| Lead                          | 1.1     | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 12:05 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 372 HIGHLAND CIRCLE Lab ID: 30758568021 Collected: 02/20/25 09:00 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.27    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 12:19 | 7440-50-8 |      |
| Lead                          | 52.9    | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 12:19 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 323 DICK SPENCER ROAD Lab ID: 30758568022 Collected: 02/20/25 06:30 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.19    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 12:32 | 7440-50-8 |      |
| Lead                          | 2.4     | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 12:32 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

| Sample: 129 DEERFIELD ROAD      Lab ID: 30758568023      Collected: 02/14/25 07:05      Received: 02/25/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|--|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters   | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW   |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8   |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver  |         |       |              |        |    |          |                |           |      |
| Copper   | 0.18    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 12:35 | 7440-50-8 |      |
| Lead   | 7.6     | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 12:35 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

| Sample: 158 SUNSET CIRCLE      Lab ID: 30758568024      Collected: 02/19/25 07:00      Received: 02/25/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|---|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters  | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW  |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8  |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver   |         |       |              |        |    |          |                |           |      |
| Copper  | 0.092   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 12:38 | 7440-50-8 |      |
| Lead  | 0.12J   | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 12:38 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 145 THIRD STREET Lab ID: 30758568025 Collected: 02/18/25 08:00 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.0023J | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 12:41 | 7440-50-8 |      |
| Lead                          | ND      | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 12:41 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 472 LAFAYETTE STREET Lab ID: 30758568026 Collected: 02/20/25 10:00 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                    | Results   | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---|-------|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |       |              |        |    |          |                |           |      |
| Copper                        | 0.20  | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 12:43 | 7440-50-8 |      |
| Lead                          | 0.39J   | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 12:43 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 305 PARK GROVE LANE Lab ID: 30758568027 Collected: 02/17/25 04:00 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                    | Results      | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|--------------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |              | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | <b>0.018</b> | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 12:46 | 7440-50-8 |      |
| Lead                          | <b>0.28J</b> | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 12:46 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 216 NORTHFIELD DRIVE Lab ID: 30758568028 Collected: 02/17/25 05:30 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.11    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 12:49 | 7440-50-8 |      |
| Lead                          | 0.17J   | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 12:49 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30758568

| Sample: 1986 BENEDICT LANE      Lab ID: 30758568029      Collected: 02/19/25 08:35      Received: 02/25/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|--|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters   | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW   |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8   |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver  |         |       |              |        |    |          |                |           |      |
| Copper   | 0.012   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 12:51 | 7440-50-8 |      |
| Lead   | ND      | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 12:51 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

| Sample: 199 MATHEWS STREET      Lab ID: 30758568030      Collected: 02/20/25 07:02      Received: 02/25/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|--|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters   | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW   |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8   |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver  |         |       |              |        |    |          |                |           |      |
| Copper   | 0.14    | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 13:00 | 7440-50-8 |      |
| Lead   | 0.82    | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 13:00 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 251 HIGHLAND CIRCLE Lab ID: 30758568031 Collected: 02/20/25 07:55 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                    | Results | Units   | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-------------------------------|---------|---|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b> |         | Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |              |        |    |          |                |           |      |
| Copper                        | 0.017   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 13:02 | 7440-50-8 |      |
| Lead                          | 0.27J   | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 13:02 | 7439-92-1 |      |

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

Sample: 186 COURT STREET SOUTH Lab ID: 30758568032 Collected: 02/19/25 07:00 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters                        | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|-----------------------------------|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| BVR 200.8 MET ICPMS DW            |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8      |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver |         |       |              |        |    |          |                |           |      |
| Copper                            | 0.036   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 13:05 | 7440-50-8 |      |
| Lead                              | 1.7     | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 13:05 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

Sample: **21647 SENECA TRAIL NORTH** Lab ID: **30758568033** Collected: 02/17/25 07:00 Received: 02/25/25 18:00 Matrix: Drinking Water

| Parameters   | Results     | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
|--|-------------|-------|--------------|--------|----|----------|----------------|-----------|------|
| <b>BVR 200.8 MET ICPMS DW</b><br>Analytical Method: EPA 200.8<br>Pace Analytical Services - Beaver |             |       |              |        |    |          |                |           |      |
| Copper   | <b>0.10</b> | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 13:08 | 7440-50-8 |      |
| Lead   | <b>0.89</b> | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 13:08 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: WV3301307  
 Pace Project No.: 30758568

| Sample: 207 RADER ROAD      Lab ID: 30758568034      Collected: 02/20/25 05:15      Received: 02/25/25 18:00      Matrix: Drinking Water |         |       |              |        |    |          |                |           |      |
|--|---------|-------|--------------|--------|----|----------|----------------|-----------|------|
| Parameters   | Results | Units | Report Limit | MDL    | DF | Prepared | Analyzed       | CAS No.   | Qual |
| BVR 200.8 MET ICPMS DW   |         |       |              |        |    |          |                |           |      |
| Analytical Method: EPA 200.8   |         |       |              |        |    |          |                |           |      |
| Pace Analytical Services - Beaver  |         |       |              |        |    |          |                |           |      |
| Copper   | 0.039   | mg/L  | 0.0025       | 0.0013 | 1  |          | 02/27/25 13:10 | 7440-50-8 |      |
| Lead   | 0.54    | ug/L  | 0.50         | 0.076  | 1  |          | 02/27/25 13:10 | 7439-92-1 |      |

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.